



Certificate of Compliance

Certificate: 1852951

Master Contract: 159409

Project: 2404698

Date Issued: March 8, 2011

Issued to: Xantrex Technology Inc
161 South Vasco Rd, Suite G
Livermore, CA 94551
USA
Attention: Mr. Ralph McDiarmid

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ramunas Wierzbicki

Issued by: Ramunas Wierzbicki

PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment
CLASS 5311 89 - POWER SUPPLIES - Distributed Generation - Power Systems Equipment
- Certified to U.S. Standards

Maximum Power Point Tracking Solar Charge Controller, Model XW-MPPT60-150, fixed installation, permanently connected, ratings as follows:

Max PV Open Circuit Voltage: 150 V

Max PV Short Circuit Current: 60 A

Range of Operating PV Voltage: 12- 140 V dc

Max. Input Current: 60 A

Nominal Battery Voltages: 12, 24, 36, 48 and 60 V dc

Max. Output Current: 60 A dc

Max Output Power: 3400 W



Certificate: 1852951

Master Contract: 159409

Project: 2404698

Date Issued: March 8, 2011

Max Ambient Operating Temperature: 45 °C

APPLICABLE REQUIREMENTS

C22.2 No. 107.1-01 – General Use Power Supplies

UL 1741 Second Edition – Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources.